



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3224</b>	6-Feb-2018	Number 3	Issue date 26-Apr-2019	30-Apr-2020
				Page 1 of 1

## Product designation

**AustubeMills, DuraPrimed, Medium, steel fire sprinkler/hydrant pipe**

## Agent/distributor

Austube Mills  
Building 7, Industrial Drive, MAYFIELD, NSW, AUSTRALIA, 2304

## Registrant

Austube Mills  
146 Ingram Road, ACACIA RIDGE, QLD, AUSTRALIA, 4110

### Producer

Austube Mills  
Building 7, Industrial Drive, MAYFIELD, NSW, AUSTRALIA, 2304

## Conformance criteria and evaluation

The AustubeMills, DuraPrimed, Medium, steel fire sprinkler/hydrant pipe has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 4118.2.1-1995, 'Fire sprinkler systems - Piping - General' incl. Amdt 1 (22 June 2005).
2. Australian Standard AS 1074-1989, 'Steel tubes and tubulars for ordinary service'.
3. Australian Standard AS 4728-2005, 'Electric resistance welded steel pipe for pressure purposes' incl. Amdt 1 (23 February 2007).

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker  
Executive Officer – ActivFire Scheme



Registration Certificate : Validation Issue

© CSIRO Australia, 2019

